



Number:	UKCA/0558/21/302	Replaces:	17GR0198/00
Issue Date:	06-12-2021	Contract Number:	PS7133
Due Date:	06-12-2031	Module:	B (Type Testing)
Report Number:	120426	Scope:	Gas Appliances
PIN:	0063BL1552	Page	1 of 3

UKCA TYPE EXAMINATION CERTIFICATE

Kiwa Ltd. hereby declares that the model type(s)

VK

Manufactured by **Elster GmbH (Honeywell)**
Lotte - Büren, Germany

Meet(s) the essential requirements as described in the:

Gas Appliances Regulation (Regulation (EU) 2016/426 as brought into GB law and amended), and the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations 2018 No 389, and amendments to UK SI 2019/696 Product Safety and Metrology, and subsequent amendments, The Product Safety, Metrology and Mutual Recognition Agreement (Amendment) (EU Exit) Regulations 2019 No 1246, and subsequent amendments. This certificate is not valid in Northern Ireland – and is applicable to England, Scotland and Wales only.

Reference standards: BS EN 161:2011+A3:2013

Signed on behalf of Kiwa Ltd.
(UK Approved Body Number 0558)

Mark Crowther
Technical Director
Kiwa Ltd.

39017601

CERTIFICATE

Kiwa Gastec
Kiwa House
Malvern View Business Park
Stella Way
Bishops Cleeve
Cheltenham
GL52 7DQ
United Kingdom
T +44 (0)1242 677877
F +44 (0)1242 676506
www.kiwa.co.uk

UK CA



0217



Number:	UKCA/0558/21/302	Replaces:	17GR0198/00
Issue Date:	06-12-2021	Contract Number:	PS7133
Due Date:	06-12-2031	Module:	B (Type Testing)
Report Number:	120426	Scope:	Gas Appliances
PIN:	0063BL1552	Page	2 of 3

APPENDIX TO UKCA TYPE EXAMINATION CERTIFICATE

List of all available types:

VK Electro-hydraulic automatic shut-off valve, class A approved on EN 161.
Mechanical strength group 2.
Ambient temperature range: -15 to +60°C
-15 to +40°C (type X)

VK ..
connection size: 40, 50, 65, 80, 100, 125,
150, 150/100, 200, 200/100, 250

R thread connection
F flange connection

Inlet pressure:

- 02	230 mbar
- 04	400 mbar
- 05	500 mbar
- 06	600 mbar
- 10	1000 mbar
- 15	1500 mbar
- 20	2000 mbar
- 24	2400 mbar
- 31	3100 mbar
- 40	4000 mbar
- 60	6000 mbar
- 80	8000 mbar

Z two step operation

Electrical connection:

- T5	220/240 Vac - 50 Hz
- W5	230 Vac - 50 Hz
- W6	230 Vac - 60 Hz
- Y	200 Vac - 50/60 Hz
- Q6	120 Vac - 60 Hz
- M	110 Vac - 50/60 Hz
- P	100 Vac - 50/60 Hz
- T5/K	220 Vac - 50Hz/24Vdc
X	Actuator in explosion-proof version
H	Version for higher input pressure



Number:	UKCA/0558/21/302	Replaces:	17GR0198/00
Issue Date:	06-12-2021	Contract Number:	PS7133
Due Date:	06-12-2031	Module:	B (Type Testing)
Report Number:	120426	Scope:	Gas Appliances
PIN:	0063BL1552	Page	3 of 3

APPENDIX TO UKCA TYPE EXAMINATION CERTIFICATE

Valve housing material:

- A	ALSi
- G	GGG 40
9	Metal connection box IP 54 with terminals
6	Connection box with standard plug
3	Rp " screw plugs at inlet and outlet
D	Flow adjustment
S	Position indicator
S2	2 Positions indicator
R	Holding relay
V	Viton valve-disc seal
F	Viewing window